

Policy No.	318 App. A
Version:	1
Issue:	07-26-11
Page:	1 of 1

SUBJECT: Policy 318 Appendix A – Application Fee Schedule

Review Level	Application Fee
Level 1 (up to 20 kVA)	\$250.00
Level 2-4 (greater than 20 kVA but no more than 100 kVA)	\$500.00
Level 2-4 (greater than 100 kVA but no more than 500 kVA)	\$1,000.00
Level 2-4 (greater than 500 kVA but no more than 2 MVA)	\$2,000.00
Level 2-4 (greater than 2 MVA)	\$5,000.00

The Cooperative shall determine whether an interconnection request should be processed under the Level 1, 2, 3 or 4 procedures by using the following screens:

**Level 1** – Lab-certified inverter-based interconnection equipment with an aggregate electric nameplate capacity less than or equal to 20.0 kVA.

**Level 2** – Lab-certified interconnection equipment with an aggregate electric nameplate capacity less than or equal to 2 MVA.

**Level 3** – Distributed generation facility does not export power. Nameplate capacity rating is less than or equal to 40 kVA if connecting to area network or less than or equal to 10 MVA if connecting to a radial distribution feeder.

**Level 4** – Nameplate capacity rating is less than or equal to 10 MVA and the distributed generation facility does not qualify for a Level 1, Level 2 or Level 3 review, or the distributed generation facility has been reviewed but not approved under a Level 1, Level 2 or Level 3 review.

\*Any review level shall meet the criteria of Section 318.7 of the Procedures for Distributed Generation Interconnection policy.

Version History			
Version	Date	Revised By	Change Description
2	04-01-22	B. Pelelo	Revise Level 1 upper limit to 20.0 kVA
1	09-25-19	J. Shekleton	-Update layout, BOD approved fee schedule. Revise 'Subject'.
0	07-26-11	K. Buros	-Original